



Product Service

Attestation of Conformity

No. N8A 082429 0148 Rev. 08

Holder of Certificate: Risen Energy Co.,Ltd

Meilin, Ninghai,
315609 Ningbo, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 704061704311-17

Date, 2020-03-26 (Zhulin Zhang)

giti

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Product Service

Attestation of Conformity

No. N8A 082429 0148 Rev. 08

Model(s):

RSM72-6-xxxM, xxx=330 to 405 in step of 5
RSM60-6-xxxM, xxx=275 to 340 in step of 5
RSM156-6-xxxM, xxx=410 to 445 in step of 5
RSM144-6-xxxM, xxx=350 to 415 in step of 5
RSM144-6-xxxM, xxx=425 to 450 in step of 5
RSM144-7-xxxM, xxx=425 to 450 in step of 5
RSM132-6-xxxM, xxx=320 to 380 in step of 5
RSM120-6-xxxM, xxx=295 to 350 in step of 5
RSM120-6-xxxM, xxx=355 to 375 in step of 5
RSM120-7-xxxM, xxx=355 to 375 in step of 5
RSM150-8-xxxM, xxx=465 to 505 in step of 5
xxx is standing for rated output power at STC

Parameters:

Construction:	Framed with Junction box, Cable and Connectors.
Test Laboratory:	Yangzhou Opto-Electrical Products Testing Institute No. 10 West Kaifa Road, Yangzhou 225009 Jiangsu, P. R. China
Safety Class:	Class II
Maximum System Voltage:	1500V DC
Fire Safety Class:	Class C according to UL790

Tested
according to:

EN IEC 61730-1:2018
EN IEC 61730-1:2018/AC:2018-00
EN IEC 61730-2:2018
EN IEC 61730-2:2018/AC:2018-00

10-60
jiri