

Tongwei Solar (Hefei) Co., Ltd.
Ms. Peng Lingling
Lab QA Dept.
No. 888 Changning Road,
High-tech District
Hefei, Anhui 230088
P. R. China

Date : 24.07.2019
Our ref. : CSS 01
Your ref.: P.L.

Ref : PV Photovoltaic Modules

Type of Equipment : PV Module
Model Designation : See Certificate
Certificate No. : PV 50442385 0001
Report No. : 50270287 001

Dear Ms. Peng Lingling,

Thank you very much for your interest in our services.


Please find enclosed your certification documents.

We appreciate your support and would like to offer our assistance in the approval of your future products through our extensive range of technical services.

Please feel free to contact us whatever your requirements may be.

With kind regards,

Certification Body


Dipl.-Ing. (TU) G. Reimann

cc: Tongwei Solar (Hefei) Co., Ltd.

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
PV 50442385

Blatt Sheet
0001

Ihr Zeichen Client Reference
P.L.

Unser Zeichen Our Reference
01-CSS-50270287 001

Ausstellungsdatum
24.07.2019

Date of Issue
(day/mo/yr)

Genehmigungsinhaber License Holder

Tongwei Solar (Hefei) Co., Ltd.
No. 888 Changning Road,
High-tech District
Hefei, Anhui 230088
P. R. China

Fertigungsstätte Manufacturing Plant

Refer to latest revision
of the annex list of factories

Prüfzeichen Test Mark



Geprüft nach Tested acc. to

EN 61215-1:2016
EN 61215-2:2017
EN 61215-1-1:2016
EN IEC 61730-1:2018
EN IEC 61730-2:2018
IEC 61215-1:2016
IEC 61215-1-1:2016
IEC 61215-2:2016
IEC 61730-1:2016
IEC 61730-2:2016

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

PV Module

6

Type Designation:

With 6" mono c-Si cells:

TWxxxMWP-72 (xxx=355-390, in steps of 5, 72 cells)

TWxxxMWP-60 (xxx=295-325, in steps of 5, 60 cells)

With 6" poly c-Si cell:

TWxxxPW-72 (xxx=310-345, in steps of 5, 72 cells)

TWxxxPW-60 (xxx=260-285, in steps of 5, 60 cells)

Remarks:

Class II acc. to IEC 61140

Max. System Voltage: up to 1000 VDC (Voc at STC)

Fire Rating: Class C

Design Load/ Safety Factors: 1600 Pa / 1.5 (upward)
3600 Pa / 1.5 (downward)

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval. The certificate is valid until 23 July 2024.

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com

Fax: +49 221 806-3935 http://www.tuv.com/safety



Zertifizierungsstelle

Dipl.-Ing. (TU) G. Reimann

**Anlage Fertigungsstättenliste
/Attachment List of Factories**



PV 50442385 0001

1 Tongwei Solar (Hefei) Co., Ltd.
No. 888 Changning Road,
High-tech District
Hefei, Anhui 230088
P. R. China


TÜVRheinland

Dieser Anhang ersetzt den Vorgänger vom/
This annex replaces the previous annex dated

Datum / Date 24.07.2019



Zertifizierungsstelle
/ Certification Body


Dipl.-Ing. (TU) G. Reimann